

Client:

Aquaknight Industries Ltd
33 Leslie Avenue
Sandringham
Auckland 1025
New Zealand

Date of Test: 12-Feb-2020

Date of Certificate: 05-10-2020

Certificate Number: FLV 014



Product Details

Model Number: 3100.405 Model Name: RD BE225

Inlet Size (mm): 225 Outlet Size (mm): 225


Description: Roof Drain Bottom Exit 225mm

Testing Conditions: Stainless Steel flange mounted flush into test plinth (datum)
Clamp Ring and grate installed
Discharge to atmosphere

**Grate
Drawing****Installed
Drawing**

Flow Characteristic Curve

Flow Characteristic Curve for: Roof Drain 225mm
Condition: Fitting only



Flow Rate (L/sec)	Water Head (mmH2O)
4.448	23.8
8.196	35.5
13.064	46.1
15.354	53.2
19.492	61.6
22.999	68.9
26.465	75.5
30.233	83.5
34.483	91.0
38.066	99.9
42.208	111.0