

Client:

Aquaknight Industries Ltd
311 Rosebank Rd
Avondale
Auckland 1026
New Zealand

Date of Test: 17-Sep-2026

Date of Certificate: 23-Sep-2026

Certificate Number: FL 165

Certificate Expiry: 23-Sep-2028

Product Details

Model Number: 2200.612 Model Name: Scupper 100 Round


Inlet Size (mm): 100 Outlet Size (mm): 100

Description: Scupper 100mm Round with guard


Testing Conditions: Scupper flange flush mounted to plinth (datum)
Scupper guard installed
Discharge to atmosphere

FITTING ONLY

**Grate
Drawing**




**Installed
Drawing**



Flow Characteristic Curve

Flow Characteristic Curve for:
2200.612 Scupper 100 Round with Scupper Guard
Condition: Fitting only



Flow Rate (L/sec)	Water Head (mmH2O)
0.610	31.0
1.020	43.0
1.500	55.0
3.100	84.0
4.400	105.0
5.500	122.0
6.700	150.0