

Client:

Aquaknight Industries Ltd
311 Rosebank Rd
Avondale
Auckland 1026
New Zealand

Date of Test: 19-Sep-2026

Date of Certificate: 23-Sep-2026

Certificate Number: FL 166

Certificate Expiry: 23-Sep-2028

Product Details

Model Number: 2200.712 Model Name: Scupper 150 Round


Inlet Size (mm): 150 Outlet Size (mm): 150

Description: Scupper Round 150mm, with guard


Testing Conditions: Scupper flange flush mounted to plinth (datum)
Scupper guard installed
Discharge to atmosphere

FITTING ONLY

**Grate
Drawing**




**Installed
Drawing**



Flow Characteristic Curve

Flow Characteristic Curve for:
2200.712 Scupper 150 Round with Scupper Guard
Condition: Fitting only



Flow Rate (L/sec)	Water Head (mmH2O)
0.610	24.0
1.190	39.0
3.010	66.0
6.050	101.0
10.260	141.0
14.140	179.0
17.250	215.0
19.830	250.0